



Indian Cardamom Research Institute

SPICES BOARD

(Government of India)
(Ministry of Commerce and Industry)

Myladumpara
Kailasanadu P.O
Idukki District - 685 553
Kerala

**भारतीय इलायची अनुसंधान संस्थान
स्पाइसेस बोर्ड**

(वाणिज्य एवं उद्योग मंत्रालय, भारत सरकार)
मैलाडुंपारा
कैलासनाड पी.ओ.
इडुक्की जिला - 685 553
केरल

No. MYL/ADM/2(1)/2021-22/MISC

16.10.2023

**SUPPLY AND INSTALLATION OF FIRE EXTINGUISHERS (ABC, CO2,FOAM TYPE
OF BIS(ISI) MARK ONLY AT ICRI CAMPUS**

Quotation Notice

Indian Cardamom Research Institute, Spices Board under Ministry of Commerce and Industry, Govt. of India invites Competitive Sealed Quotations for installing “**Fire Extinguishers**” in the Server rooms, Laboratories, Generator room and other Domestic areas of ICRI campus. The total number of Fire Extinguishers to be installed along with the details is given below. The quotations shall be sent in a sealed cover super scribing “**Quotation for Installation of Fire Extinguishers**” to the Director (Research), Indian Cardamom Research Institute, Spices Board Myladumpara, Kailasanadu (P.O), Idukki 685 553, so as to reach on or before 02 Nov 2023 by 4 pm.

Technical Specifications and other details for Fire Extinguishers

Sl No	Main Features	Detailed Specifications
		Fire Extinguishers required for putting out fire related incidents in the Server rooms, Laboratories, Generator room and other Domestic areas of ICRI campus.
1	Quantity	10 Nos
2	Type & Capacity(KG)	As mentioned below
	Type	Capacity
	CO2	02 kg – 04 Nos, 04 Kg-01 No
	DCP	02 Kg – 04 Nos, 04 Kg – 01 No
3	Extinguisher Type	(DCP/CO2) as applicable to the locations/Work area specified
4	Certification	BIS (ISI)
5	Fire class	A, B, C
6	Brand	Certified Brands.
7	Warranty	Minimum 02 years from the date of installation.
8	Installation, Servicing, Training	Installation and Commissioning of extinguishers is required by certified fire extinguisher service engineer. Training shall be arranged post installation.
9	Performance Guarantee	a. The agency should have executed two similar works. b. The agency should have work experience since last 05 years.

Phone: Office: 04868-237206 & 237207; Fax: 04868-237285


E-mail: icrimyladumpara@gmail.com

Website: www.indianspices.com

Terms and Conditions.

1. The rate may be quoted for the installation of Fire Extinguishers including the Annual Maintenance Contract, Provision of instruction labels, quoted separately in the quotation for further comparison and evaluation. Rate for the installation and Annual Maintenance Contract may mention separately.
2. The rate may be quoted including labour charges and freight charges if any.
4. Quotations will be opened on 06 Nov 2023 at 11 am by the committee. There shall not be any further intimation regarding the opening of the same.
5. Successful bidder should install the equipments within 7 days of the receipt of the order from this office
6. The email id mobile number and communication address of the bidder should be provided on the envelope as well.
7. The ICRI, Spices Board reserves all rights to reject any or all the quotations without assigning any reason thereof.




Director (Research)